



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3

Tabella Medie Giornaliere per Enti esterni

Mese FEBBRAIO-2018

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		180		180		15		
1	0	*		*		*		*		*
2	0	*		*		*		*		*
3	0	*		*		*		*		*
4	0	*		*		*		*		*
5	0	*		*		*		*		*
6	0	*		*		*		*		*
7	9	49,96	100	119,82	100	103,92	100	6,99	100	11.533.485,60
8	24	54,77	100	128,50	100	124,25	100	10,51	100	35.460.479,68
9	24	36,80	100	115,83	100	114,94	100	9,37	100	34.042.398,97
10	24	25,93	100	132,15	100	116,48	100	9,73	100	32.198.610,13
11	24	27,68	100	132,89	100	115,28	100	8,05	100	32.502.286,41
12	24	49,42	100	133,83	100	119,73	100	9,30	100	36.828.554,57
13	24	32,53	100	132,17	100	121,96	100	9,82	100	36.669.960,85
14	24	44,70	100	134,07	100	128,87	100	9,08	100	38.983.885,28
15	24	53,01	100	123,71	100	133,48	100	9,64	100	38.898.525,86
16	24	30,61	100	132,66	100	133,98	100	8,43	100	36.832.935,76
17	24	33,06	100	127,63	100	130,42	100	7,45	100	34.428.134,24
18	24	22,81	100	122,51	100	131,55	100	8,96	100	31.593.825,67
19	24	29,64	100	119,19	100	132,19	100	10,28	100	34.304.016,85
20	24	47,54	100	83,31	100	114,26	100	8,99	100	35.274.856,66
21	24	82,68	100	134,06	100	123,66	100	7,81	100	37.087.438,43
22	24	96,65	100	149,38	100	129,94	100	8,04	100	38.663.281,95
23	24	77,17	100	131,88	100	136,98	100	9,41	100	38.118.696,75
24	24	89,71	100	133,79	100	127,42	100	9,90	100	39.608.338,92
25	24	53,08	100	140,73	100	123,10	100	8,81	100	35.599.595,08
26	24	93,97	100	138,27	100	128,38	100	9,89	100	38.797.862,50
27	24	91,52	100	131,68	100	130,42	100	10,62	100	39.332.698,46
28	24	82,90	91,67	146,51	91,67	139,41	91,67	8,61	100	40.005.070,15
Valore Mese	513	54,86	99,61	129,51	99,61	126,06	99,61	9,14	100	776.764.938,78

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------