



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3

Tabella Medie Giornaliere per Enti esterni

Mese GIUGNO-2018

Dati Ricalcolati NAS

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		180		180		15		
1	0	*		*		*		*		*
2	0	*		*		*		*		*
3	0	*		*		*		*		*
4	0	*		*		*		*		*
5	0	*		*		*		*		*
6	0	*		*		*		*		*
7	0	*		*		*		*		*
8	0	*		*		*		*		*
9	0	*		*		*		*		*
10	0	*		*		*		*		*
11	0	*		*		*		*		*
12	0	*		*		*		*		*
13	0	*		*		*		*		*
14	0	*		*		*		*		*
15	0	*		*		*		*		*
16	0	*		*		*		*		*
17	0	*		*		*		*		*
18	17	1,53	100	124,08	100	116,88	100	0,18	100	19.954.765,42
19	24	58,96	95,83	130,78	95,83	118,83	95,83	2,14	95,83	33.640.395,30
20	24	58,18	100	114,72	100	118,81	100	3,94	100	37.724.076,08
21	24	33,79	100	113,25	100	124,79	100	2,67	100	38.309.198,95
22	24	31,97	100	130,52	100	126,44	100	1,65	100	37.910.554,74
23	2	N.A.	100	N.A.	100	N.A.	100	N.A.	100	2.531.413,90
24	0	*		*		*		*		*
25	0	*		*		*		*		*
26	0	*		*		*		*		*
27	0	*		*		*		*		*
28	0	*		*		*		*		*
29	0	*		*		*		*		*
30	0	*		*		*		*		*
Valore Mese	115	N.A.	99,13	N.A.	99,13	N.A.	99,13	N.A.	99,13	170.070.404,41

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------