



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3

Tabella Medie Giornaliere per Enti esterni

Mese LUGLIO-2018

Dati Ricalcolati NAS

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		180		180		15		
1	0	*		*		*		*		*
2	0	*		*		*		*		*
3	0	*		*		*		*		*
4	0	*		*		*		*		*
5	0	*		*		*		*		*
6	0	*		*		*		*		*
7	0	*		*		*		*		*
8	0	*		*		*		*		*
9	0	*		*		*		*		*
10	16	92,87	100	128,17	100	123,64	100	4,10	100	25.400.203,34
11	24	49,16	100	125,38	100	124,93	100	4,65	100	35.883.446,93
12	24	37,83	100	119,57	100	123,49	100	4,11	100	32.082.948,91
13	24	68,16	100	132,18	100	123,04	100	4,03	100	37.285.792,35
14	24	4,88	100	127,22	100	134,00	100	0,68	100	27.565.147,38
15	24	10,86	100	128,21	100	132,70	100	1,53	100	29.098.447,73
16	24	9,99	100	128,96	100	128,33	100	1,24	100	32.444.076,86
17	24	25,12	100	132,23	100	130,60	100	0,57	100	33.413.757,82
18	24	34,15	100	132,50	100	126,52	100	1,09	100	36.110.931,29
19	24	28,04	100	124,92	100	133,33	100	0,25	100	33.235.524,30
20	24	35,70	100	138,71	100	131,72	100	0,38	100	36.919.702,89
21	22	6,18	100	123,49	100	140,67	100	0,01	100	25.298.780,31
22	0	*		*		*		*		*
23	0	*		*		*		*		*
24	0	*		*		*		*		*
25	0	*		*		*		*		*
26	0	*		*		*		*		*
27	0	*		*		*		*		*
28	0	*		*		*		*		*
29	0	*		*		*		*		*
30	16	43,53	100	134,73	100	127,76	100	2,55	100	24.096.974,82
31	24	68,75	100	136,72	100	135,16	100	1,43	100	37.337.755,05
Valore Mese	318	35,41	100	129,44	100	129,84	100	1,84	100	446.173.489,97

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------