



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3

Tabella Medie Giornaliere per Enti esterni

Mese AGOSTO-2016

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		180		180		15		
1	0	*		*		*		*		*
2	0	*		*		*		*		*
3	0	*		*		*		*		*
4	0	*		*		*		*		*
5	0	*		*		*		*		*
6	22	8,16	100	96,50	100	137,27	100	1,62	100	26.843.455,00
7	24	12,61	100	93,38	100	124,89	100	1,47	100	30.034.851,75
8	24	47,25	91,67	120,01	91,67	156,13	91,67	3,16	91,67	37.124.776,13
9	24	59,33	100	114,83	100	143,75	100	3,39	100	38.819.960,00
10	24	26,73	100	99,04	100	148,69	100	3,24	100	35.357.631,25
11	24	19,05	100	107,85	100	150,68	100	2,52	100	35.661.597,50
12	23	1,48	100	72,71	100	142,15	100	1,40	100	26.503.781,00
13	0	*		*		*		*		*
14	0	*		*		*		*		*
15	0	*		*		*		*		*
16	0	*		*		*		*		*
17	0	*		*		*		*		*
18	0	*		*		*		*		*
19	0	*		*		*		*		*
20	0	*		*		*		*		*
21	0	*		*		*		*		*
22	12	1,03	100	70,44	100	149,62	100	2,93	100	14.252.868,38
23	0	*		*		*		*		*
24	0	*		*		*		*		*
25	0	*		*		*		*		*
26	0	*		*		*		*		*
27	0	*		*		*		*		*
28	0	*		*		*		*		*
29	0	*		*		*		*		*
30	0	*		*		*		*		*
31	0	*		*		*		*		*
Valore Mese	177	23,38	98,87	98,53	98,87	143,73	98,87	2,44	98,87	244.598.921,00

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------