



**Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3**

Tabella Medie Giornaliere per Enti esterni

Mese APRILE-2017

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		180		180		15		
1	17	7,20	100	73,61	100	137,68	100	6,38	100	20.700.523,52
2	20	10,80	100	72,23	100	139,87	100	5,33	100	23.620.109,32
3	24	16,75	100	62,55	100	133,92	100	5,65	100	31.363.832,76
4	24	20,94	100	68,95	100	131,51	95,83	6,89	100	34.719.822,26
5	24	8,71	100	69,94	100	133,84	100	8,34	100	32.239.254,68
6	24	7,70	100	107,92	100	134,23	100	9,09	100	31.929.726,44
7	24	29,07	100	111,77	100	137,74	100	8,42	100	32.034.704,94
8	24	10,87	100	99,53	100	143,48	100	7,92	100	28.760.315,95
9	24	6,94	100	106,75	100	139,92	100	6,36	100	25.996.826,40
10	24	10,33	100	83,64	100	131,48	100	6,08	100	27.941.308,42
11	24	10,86	100	126,01	100	132,20	100	6,62	100	27.779.835,28
12	24	9,81	100	130,28	100	135,42	100	7,12	100	26.874.413,33
13	24	11,91	100	123,38	100	140,42	100	6,27	100	27.301.174,77
14	24	7,63	100	125,32	100	145,38	100	5,41	100	26.112.334,24
15	24	10,02	100	127,96	100	141,71	100	5,70	100	26.716.470,13
16	24	20,24	100	135,79	100	136,81	100	4,90	100	27.050.402,31
17	24	41,07	100	144,46	100	124,46	100	5,83	100	33.392.807,62
18	24	24,65	100	148,24	100	137,10	100	7,65	100	31.426.113,31
19	24	16,84	100	141,88	100	141,48	100	7,33	100	30.892.675,27
20	24	12,89	100	102,95	100	141,46	100	6,01	100	28.984.061,75
21	0	*		*		*		*		*
22	0	*		*		*		*		*
23	0	*		*		*		*		*
24	0	*		*		*		*		*
25	0	*		*		*		*		*
26	0	*		*		*		*		*
27	0	*		*		*		*		*
28	0	*		*		*		*		*
29	0	*		*		*		*		*
30	0	*		*		*		*		*
Valore Mese	469	14,91	100	108,98	100	136,98	99,79	6,68	100	575.836.712,73

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------