



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3

Tabella Medie Giornaliere per Mese

Mese GENNAIO-2018

Giorno	Ore di Normale Funzionamento	CO nor		SO2 nor		NOX nor		POLV nor		O2	
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Misurato vol%	Rif. vol%
Limite applicabile		150		180		180		15			
1	0	*		*		*		*		*	*
2	0	*		*		*		*		*	*
3	0	*		*		*		*		*	*
4	0	*		*		*		*		*	*
5	0	*		*		*		*		*	*
6	0	*		*		*		*		*	*
7	0	*		*		*		*		*	*
8	0	*		*		*		*		*	*
9	8	8,48	100	87,23	100	113,25	100	6,21	100	10,59	6,00
10	24	40,74	100	124,89	100	126,35	100	6,94	100	9,56	6,00
11	24	78,44	100	146,00	100	117,17	100	7,11	100	9,41	6,00
12	24	30,89	100	145,25	100	121,19	100	5,10	100	9,42	6,00
13	24	25,28	100	128,36	100	120,11	100	4,88	100	9,49	6,00
14	24	33,90	100	140,74	100	120,06	100	5,63	100	9,23	6,00
15	24	26,94	100	134,79	100	121,58	100	5,16	100	9,58	6,00
16	24	40,20	100	135,99	100	122,17	100	5,21	100	9,45	6,00
17	24	15,32	100	137,64	100	123,65	100	5,63	100	9,61	6,00
18	23	18,14	100	133,24	100	136,81	100	5,04	100	9,58	6,00
19	0	*		*		*		*		*	*
20	0	*		*		*		*		*	*
21	0	*		*		*		*		*	*
22	0	*		*		*		*		*	*
23	0	*		*		*		*		*	*
24	0	*		*		*		*		*	*
25	0	*		*		*		*		*	*
26	0	*		*		*		*		*	*
27	0	*		*		*		*		*	*
28	0	*		*		*		*		*	*
29	0	*		*		*		*		*	*
30	0	*		*		*		*		*	*
31	0	*		*		*		*		*	*
Valore Mese	223	33,57	100	134,57	100	122,81	100	5,66	100	9,52	6,00

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------