



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3

Tabella Medie Giornaliere per Enti esterni

Mese GIUGNO-2016

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		180		180		15		
1	24	60,49	100	122,84	100	142,19	100	1,90	100	35.570.784,88
2	24	7,62	100	112,72	100	147,42	100	1,27	100	29.239.099,63
3	23	44,03	100	100,50	100	143,05	100	1,10	100	33.863.938,50
4	0	*		*		*		*		*
5	0	*		*		*		*		*
6	0	*		*		*		*		*
7	12	12,68	100	58,52	100	124,64	100	0,56	100	13.046.814,25
8	24	5,74	100	73,43	100	143,82	100	0,93	100	27.109.983,25
9	24	51,80	100	72,61	100	145,73	100	1,46	100	36.576.646,50
10	24	21,31	100	90,69	100	134,42	100	1,02	100	30.138.408,38
11	11	5,21	100	68,02	100	142,80	100	1,72	100	12.477.386,38
12	0	*		*		*		*		*
13	13	22,99	100	75,88	100	121,52	100	0,85	100	17.382.646,25
14	24	17,52	100	83,87	100	131,61	100	0,98	100	30.923.532,25
15	24	26,35	100	88,90	100	134,41	100	1,42	100	34.913.337,38
16	24	14,29	100	89,95	100	131,98	100	1,91	100	32.052.329,00
17	24	11,79	100	82,64	100	130,34	100	1,44	100	31.755.112,88
18	24	3,14	100	49,25	100	132,60	100	1,05	100	27.741.671,00
19	24	2,10	100	49,54	100	142,22	100	1,05	100	26.901.059,75
20	24	27,76	100	73,30	100	120,78	100	1,13	100	32.455.704,38
21	24	39,42	100	103,19	100	145,17	100	2,07	100	36.004.873,38
22	24	43,15	100	108,50	100	148,01	100	1,61	100	35.429.580,50
23	24	31,20	100	97,56	100	139,53	100	2,03	100	35.490.310,38
24	24	42,83	100	100,32	100	142,15	100	2,70	100	37.046.557,50
25	24	17,68	100	79,64	100	148,66	100	1,90	100	30.911.144,75
26	24	3,12	100	72,76	100	150,21	100	1,44	100	27.442.101,50
27	24	58,87	100	97,91	100	136,20	100	2,32	100	37.349.931,38
28	24	46,86	100	104,01	100	139,32	100	3,38	100	37.067.345,63
29	24	38,96	100	119,48	100	141,53	100	3,80	100	37.400.318,00
30	24	37,86	100	108,73	100	138,35	100	3,21	100	39.052.579,25
Valore Mese	587	27,53	100	89,12	100	138,90	100	1,74	100	805.343.196,88

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------