



Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3
 Tabella Medie Giornaliere per Enti esterni
 Mese LUGLIO-2017

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		180		180		15		
1	24	9,32	100	91,63	100	108,40	100	4,64	100	26.399.940,51
2	24	16,19	100	111,60	100	116,12	100	4,44	100	29.149.747,01
3	24	8,97	100	115,35	100	124,51	100	3,81	100	27.408.214,69
4	24	51,70	100	127,43	100	118,57	100	4,36	100	33.687.986,18
5	24	58,70	100	122,66	100	108,48	100	5,65	100	38.558.717,83
6	24	70,19	100	101,11	100	110,38	100	5,97	100	38.312.550,79
7	24	52,61	100	102,11	100	108,12	100	6,05	100	36.517.075,49
8	24	42,57	100	117,61	100	124,35	100	5,56	100	34.246.109,48
9	24	21,61	100	130,29	100	124,45	100	4,94	100	31.904.358,53
10	24	81,38	100	138,85	100	110,92	100	5,30	100	40.125.832,94
11	11	39,64	100	110,57	100	124,82	100	4,90	100	14.411.308,04
12	0	*		*		*		*		*
13	0	*		*		*		*		*
14	0	*		*		*		*		*
15	0	*		*		*		*		*
16	0	*		*		*		*		*
17	0	*		*		*		*		*
18	0	*		*		*		*		*
19	0	*		*		*		*		*
20	0	*		*		*		*		*
21	0	*		*		*		*		*
22	0	*		*		*		*		*
23	0	*		*		*		*		*
24	0	*		*		*		*		*
25	0	*		*		*		*		*
26	0	*		*		*		*		*
27	0	*		*		*		*		*
28	0	*		*		*		*		*
29	0	*		*		*		*		*
30	0	*		*		*		*		*
31	0	*		*		*		*		*
Valore Mese	251	41,25	100	115,63	100	115,84	100	5,06	100	350.721.841,49

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------