



## Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3

Tabella Medie Giornaliere per Enti esterni

Mese MAGGIO-2018

Dati Ricalcolati NAS

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		180		180		15		
1	0	*		*		*		*		*
2	0	*		*		*		*		*
3	0	*		*		*		*		*
4	0	*		*		*		*		*
5	0	*		*		*		*		*
6	0	*		*		*		*		*
7	0	*		*		*		*		*
8	0	*		*		*		*		*
9	0	*		*		*		*		*
10	0	*		*		*		*		*
11	0	*		*		*		*		*
12	0	*		*		*		*		*
13	0	*		*		*		*		*
14	0	*		*		*		*		*
15	0	*		*		*		*		*
16	0	*		*		*		*		*
17	0	*		*		*		*		*
18	0	*		*		*		*		*
19	0	*		*		*		*		*
20	0	*		*		*		*		*
21	1	N.A.	100	N.A.	100	N.A.	100	N.A.	100	1.190.716,59
22	24	22,70	100	131,81	100	127,70	100	1,33	100	30.369.972,00
23	24	34,19	100	135,10	100	125,16	100	1,26	100	29.815.194,86
24	24	39,43	100	140,95	100	128,45	100	1,04	100	31.555.925,49
25	23	14,15	100	130,83	100	133,73	100	0,39	100	29.627.880,29
26	0	*		*		*		*		*
27	0	*		*		*		*		*
28	0	*		*		*		*		*
29	0	*		*		*		*		*
30	0	*		*		*		*		*
31	0	*		*		*		*		*
Valore Mese	96	N.A.	100	N.A.	100	N.A.	100	N.A.	100	122.559.689,23

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------