



**Enel - Centrale di La Spezia - Sezione Termoelettrica n. 3**

Tabella Medie Giornaliere per Enti esterni

Mese OTTOBRE-2018

Dati Ricalcolati NAS

Giorno	Ore di Normale Funz.	CO nor		SO2 nor		NOX nor		POLV nor		QFU nor
		mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	mg/Nmc	id %	Nmc
Limite applicabile		150		180		180		15		
1	24	17,05	100	138,28	100	140,42	100	0,97	100	36.810.741,52
2	24	7,79	100	139,96	100	128,86	100	1,55	100	37.400.866,37
3	24	7,61	100	134,08	100	128,39	100	2,20	100	39.329.191,17
4	24	4,17	100	135,13	100	128,10	100	1,52	100	36.478.488,99
5	24	5,26	100	137,06	100	127,25	100	1,75	100	39.450.715,13
6	24	4,49	100	139,16	100	127,76	100	1,28	100	39.137.009,00
7	24	7,06	100	133,89	100	132,08	100	1,11	100	36.648.723,81
8	24	13,03	100	135,75	100	129,39	100	1,36	100	37.245.079,79
9	24	10,20	100	130,33	100	133,01	100	1,49	100	39.119.551,88
10	24	15,10	100	138,56	100	143,15	100	0,65	100	39.169.757,88
11	24	32,10	100	137,97	100	133,47	100	0,55	100	38.786.090,76
12	13	35,80	100	129,06	100	137,72	100	0,34	100	17.515.967,69
13	0	*		*		*		*		*
14	0	*		*		*		*		*
15	0	*		*		*		*		*
16	0	*		*		*		*		*
17	0	*		*		*		*		*
18	0	*		*		*		*		*
19	0	*		*		*		*		*
20	0	*		*		*		*		*
21	0	*		*		*		*		*
22	2	N.A.	100	N.A.	100	N.A.	100	N.A.	100	2.206.396,97
23	24	71,20	100	142,51	100	131,45	100	7,39	100	36.438.100,44
24	15	57,46	100	136,98	100	135,28	100	6,29	100	21.549.516,84
25	0	*		*		*		*		*
26	0	*		*		*		*		*
27	0	*		*		*		*		*
28	0	*		*		*		*		*
29	0	*		*		*		*		*
30	0	*		*		*		*		*
31	0	*		*		*		*		*
Valore Mese	318	18,90	100	136,59	100	132,16	100	1,96	100	497.286.198,26

N.A. Media non applicabile	N.D. Non disponibile	* Media non valida x VLE
----------------------------	----------------------	--------------------------